

Reports

Earthquakes, Faults, and Nuclear Power Plants in Southern New York and Northern New Jersey

Abstract. *Seismic activity in the greater New York City area is concentrated along several northeast-trending faults of which the Ramapo fault appears to be the most active. Three nuclear power plants at Indian Point, New York, are situated close to the Ramapo fault. For a reactor site in use for 40 years, the probability that the site will experience an intensity equal to or in excess of the design (safe shutdown) earthquake is estimated to be about 5 to 11 percent.*

The Ramapo fault system, which bounds the Triassic-Jurassic Newark graben on its northwest side, has been known for about 100 years but has been commonly presumed to be an inactive fault. Prior to the advent of plate tectonic concepts in the late 1960's, Triassic deformation was generally thought to be "the last dying gasp of Paleozoic orogeny." The separation of North America from Africa in the Triassic-Jurassic is now generally recognized as the last great tectonic event in the area, which greatly influenced the subsequent geologic history. The hypothesis that the fault is dead now appears to have been tenable only in the near absence of local instrumental earthquake data. Although a number of workers since 1964 (1) have suggested correlation of earthquakes with this and other nearby faults, the data were insufficient to definitely establish such correlations. The recent improvement in the seismographic coverage for this area enabled us to determine precise locations for 33 earthquakes and many focal mechanism solutions. The results clearly indicate that seismic activity is related to faults that trend northeast to north-northeast.

More people live within 80 km of the Indian Point reactors than within the same distance from any other nuclear power plant in the United States. The reactors are situated within 1 km of a major branch of the Ramapo fault system. As late as 1972, however, the Final Environmental Statement (2) for Indian Point reactor unit 2 stated, "There are no truly major faults in or near the site." This view was disputed by the State of New York, and that concern led to hearings on seismic safety held before the Atomic Safety and Licensing Appeal Board

(ASLAB) of the Nuclear Regulatory Commission (NRC) in 1976 and 1977. In 1975 Ratcliffe (3) recognized an individual fault, possibly of the Ramapo system, that passes beneath reactor unit 3. Since then, considerable effort has been devoted to geologic mapping and studies of local earthquakes near the reactors (2, 4-6). Since late 1976, several shocks have occurred on the Ramapo fault both to the southwest and northeast of the plant as well as almost directly beneath it.

Scientific information and judgment are intimately involved in several of the questions litigated in the NRC hearings on Indian Point. Since we participated as

scientific experts in these hearings, we also briefly summarize our views about some of the difficulties encountered in applying the existing federal regulations known as Appendix A, "Seismic and Geologic Siting Criteria for Nuclear Power Plants" (7), to sites in the East.

Figure 1 shows earthquakes in the northeastern United States and adjacent parts of Canada from 1970 to 1977 as detected by networks in the area. Since 1970 the number of seismic stations in this region has steadily increased. For the period covered in Fig. 1 the station coverage is more complete for New York State and adjacent areas and poorer for New England. For New York and adjacent areas the detection is probably complete for events larger than magnitude (m_b) 2. Since 1974 the detection is complete for $m_b > 1.8$ for the area near the Ramapo fault. We determined the magnitudes (m_b) of these and other events used in this report, using Nuttli's scale (8).

The overall spatial distribution of these events is remarkably similar to that of historical events for the period 1534 through 1959 (9). Both the record in Fig. 1 and the historic shocks show concentrations of seismic activity in the northern, western, and southeastern parts of New York State; the central part of the state is essentially aseismic.

Earthquake locations, faults, and focal mechanism solutions for southeastern New York and northern New Jersey are shown in Fig. 2. A more detailed description of the seismic data is given else-




Fig. 1. Epicenters of earthquakes (1970 through 1977) in northeastern North America located by various networks in the area. Note the northeast alignment of earthquakes in northern New Jersey and southern New York. Stars denote events of unknown origin.

where (6, 10). Figure 2 shows 33 events ($1.0 \leq m_b \leq 3.3$) for the period 1962 to 1977 located with an accuracy of 5 km or better. Instrumental data for events prior to 1962 were generally found to be insufficient to allow us to meaningfully investigate their possible correlation with faults.

Figure 2 shows a strong spatial correlation of epicentral locations with surface traces of faults in this area. A large majority of the events lie on or very close (within 1 to 2 km) to the faults. Furthermore, an examination of the focal mechanism solutions shows that for each solution one of the nodal planes trends north to northeast, which is also the predominant trend of the faults in this area. This remarkable spatial correlation and the consistency of the nodal planes with the trend of the mapped faults leave little doubt that earthquakes in this area occur along preexisting faults.

About half of the events plotted in Fig. 2 are almost colinear and lie along or close to the Ramapo fault system. The Ramapo fault system can be traced as a single continuous fault between point A and event 26; near event 26 it splays into a number of branches (5, 11). One of these branches (the Thiells fault) passes within 1 km of Indian Point (triangle in Fig. 2). The association of seismic activity with this major fault system is particularly clear in Fig. 3, where the hypocenters of events with reliable focal depths are projected onto a vertical cross section perpendicular to the trend of the fault. The southeasterly dip of the hypocenters in Fig. 3 agrees with the dip of the faults determined from focal mechanisms and geologic evidence (4, 5).

Relatively little activity is found within the Triassic Newark basin, the area between the Ramapo fault and the Hudson

River (Fig. 2). Similarly, very little activity (Figs. 1 and 2) is found to the northwest of the line connecting events 4 and 7. Some activity is found to the southeast of the Ramapo fault in the area east of the Hudson River. Hence, most of the activity in Fig. 2 is located within and bounding the Precambrian Hudson Highlands.

The Ramapo fault system has experienced at least four periods of movement from Precambrian to Jurassic time (11). Although Triassic-Jurassic movement has not been demonstrated along the Ramapo fault on the east side of the Hudson River, seismic activity is nearly continuous along the entire zone A-A'. Figure 3 indicates that seismic slip on the Ramapo fault extends to a depth of about 10 km. In contrast, much of the seismic activity northwest of the Ramapo fault occurs at shallow depths (1 to 2 km) and is of swarm type. This evidence suggests that the Ramapo fault may have a greater seismic potential than adjacent faults northwest of it.

Focal mechanism solutions indicate that high-angle reverse faulting is the predominant mode of contemporary fault movement in this area; this differs from the sense of movement during the Triassic-Jurassic (4, 5, 11). Thus, the state of stress in this area has changed with time. The present maximum compressive stress direction is nearly uniform and trends west-northwest and indicates reactivation of southeast- or northwest-dipping faults.

In a plate tectonic framework, the east coast of North America was located along a plate boundary during the Triassic but is presently a region interior to a lithospheric plate. In a worldwide study of intraplate phenomena, Sykes (12) found that intraplate earthquakes, such as those in eastern North America, tend to occur along major preexisting faults that were reactivated by continental fragmentation in the Mesozoic or Cenozoic eras. Many of these reactivated faults are still seismically active today but, of course, not to the extent that they were during the initial stages of continental rifting.

On the basis of focal mechanism solutions, Aggarwal (10) postulated that the activity in the New York City area may belong to a larger seismotectonic province extending southwesterly to Virginia approximately along the Fall Line. Cretaceous and Cenozoic deformation is found along that zone in Delaware, Maryland, and Virginia (13). The abrupt changes in the courses of several major rivers near the Fall Line have been at-




Fig. 2. Fault map (4, 5, 29) of southeastern New York and northern New Jersey showing epicenters (circles) of instrumentally located earthquakes from 1962 through 1977. Indicated uncertainties (ERH) in epicentral locations represent approximately two standard deviations. Focal mechanism solutions are upper-hemisphere plots; the dark area represents the compressional quadrant. For event 14 there are two possible focal mechanism solutions; the data, however, are more consistent with solution *b* than *a*. The Ramapo fault and two of its major branches (A-A') are shown by the heavy lines; x's denote locations for other events discussed in the text. The solid triangle shows the location of the Indian Point nuclear power reactors.

tributed to Cenozoic deformation (14), possibly along reactivated northeast-trending faults.

Although the instrumentally located events in Fig. 2 are small in magnitude and cover only a 15-year time span, the historic record of felt shocks shows that much larger earthquakes have occurred in the greater New York City area. Among the larger events known to have occurred during the last 250 years are three shocks (1737, 1884, and 1927) of intensity VII on the modified Mercalli (MM) scale and three (1783, 1895, and 1957) of intensity VI. Since precisely located shocks of the last 15 years show such a close relationship to northeast-trending faults, the larger felt shocks, for most of which precise locations are not available, are most reasonably interpreted as occurring along the same faults. In other areas where a longer record of instrumental locations is available, larger shocks show an even greater tendency than smaller shocks to be localized on major throughgoing faults (15).

Large uncertainties are inherent in efforts to locate earthquakes solely from felt reports (9); consequently, the larger events cannot be unequivocally associated with a specific fault. Within the uncertainty in the data, however, some of these events may have occurred on the Ramapo fault. The 1884 shock was felt from Maryland to New Hampshire; fallen bricks and cracked plaster were reported at 30 sites from eastern Pennsylvania to central Connecticut. Although two recent catalogs (9, 16) place the epicenter in Brooklyn, New York, both list Rockwood (17) as their original source of data. He placed the center of the zone of maximum shaking in northeastern New Jersey. An epicentral location in that area is supported by newspaper reports of foreshocks that were felt in Paterson, New Jersey (18). Felt reports for the 1737 shock are much more limited. The smaller felt area of the 1927 event places it somewhere along the north shore of New Jersey near Asbury Park, well off the Ramapo fault.

Felt reports for shocks in 1895 and 1957 and limited instrumental data for 1957 ($m_b = 4.4$) indicate that they occurred near the southwest end of the Ramapo fault near point A in Fig. 2. The 1783 earthquake was located by Smith (9) in New Jersey near the Ramapo fault. In addition, felt reports and limited instrumental data indicate that an earthquake ($m_b = 3.9$) in 1951 occurred about 8 km northwest of the Ramapo fault and a shock of $m_b = 3$ in 1947 occurred on or close to the fault (Fig. 2).

Thus, on the basis of the precise locations in Fig. 2, the 120-km length of the Ramapo fault, and the history of felt shocks in the area, we conclude that the




Fig. 3. Composite (stacked) vertical cross section showing focal depths and focal mechanism solutions (the dark area is the compressional quadrant) for events within 10 km of the Ramapo fault trace. The event number is keyed to the epicenter number in Fig. 2; only those events are plotted for which reliable focal depths could be determined. Bars represent one standard deviation. Northeast of epicenter 26 (Fig. 2) horizontal distance is measured from one of two major branches of the fault on the basis of focal mechanism solutions.




Fig. 4. Cumulative number (N) of earthquakes of magnitude m_b or greater per year as a function of magnitude. Data sets are each for the 120-km-long segment of the Ramapo fault and for shocks located within 10 km of the fault. The question mark denotes the minimum value, that is, the incomplete detectability of events of that magnitude. The slope of the curve, 0.73, was determined independently for recent shocks in New York and adjacent areas. The intensity-magnitude relationship is from (19). The uncertainty, ± 0.13 , in the value of a ($\log N = a - bm_b$) represents the 95 percent confidence interval.

Ramapo fault is capable of generating an earthquake of at least intensity VII, the nominal design earthquake of the Indian Point reactors. The relatively short period of historical data (about 250 years) is not sufficient to establish an upper bound to the size of shocks for a particular region unless some geologic or tectonic criteria are invoked.

Perhaps the most important question involving earthquakes and the seismic safety of Indian Point is: How active is the Ramapo fault? We calculate the probability of occurrence (Fig. 4) of earthquakes of intensity VII and VIII within 10 km of the fault by extrapolating the occurrence of smaller shocks to larger magnitudes using the well-known relationship $\log N = a - bM$, where N is the cumulative frequency of shocks, M is the magnitude, and a and b are constants. The b value, 0.73, was obtained for shocks recorded throughout New York and New Jersey (10) and is assumed to be applicable to this subregion. The \times 's in Fig. 4 represent the rate of occurrence of shocks within 10 km of the Ramapo fault between points A and A' that occurred from 1974 to 1977. We fitted the solid line through the \times 's, using the slope 0.73.

To check the predictability of the frequency-magnitude relationship thus determined, the rates of occurrence of historical events discussed earlier are shown in Fig. 2 for three different periods. We estimated the magnitudes of the historical events from the following relation between intensity (I) and magnitude, $m_b = -0.20 \pm 0.05 + (0.75 \pm 0.03)I$, for the East Coast (19). The rates of occurrence of events for the periods 1947 to 1977 (1951 and 1957 earthquakes) and 1887 to 1977 (1957, 1895, and 1884 earthquakes) are in excellent agreement with those predicted by the solid line (Fig. 4). Squares (Fig. 4) indicate the rate of occurrence of events up to intensity VII for the period 1737 through 1977 if both the 1737 and 1884 (MM VII) earthquakes occurred on or near the fault.

For the entire fault, the relationship between N and m_b predicts shocks of MM \geq VII about once per 97 years, if no upper bound is placed on the maximum size of possible earthquakes. If, however, we assume that shocks of MM \geq IX or MM \geq VIII cannot occur, then the corresponding recurrence times for MM \geq VII are about 105 and 137 years. These estimates are subject to possible systematic errors in determining magnitude, to uncertainties in the relation between m_b and I and the b value, and to possible errors in extrapolating

Table 1. Probability of equaling or exceeding intensities VII and VIII at Indian Point.

Method	Estimated recurrence time (years)		Probability for exposure interval of 40 years (%)	
	VII	VIII	VII	VIII
1. Earthquake frequency-magnitude relationship (Fig. 4)				
a. Events within 10 km of site only:				
No upper bound on size of events	580	2050	6.7	2.0
Excluding events of MM \geq IX	630	2870	6.1	1.4
Excluding events of MM \geq VIII	810		4.8	
b. Events along entire Ramapo fault:				
No upper bound on size of events	300	1050	12.5	3.7
Excluding events of MM \geq IX	340	1880	11.1	2.1
Excluding events of MM \geq VIII	530		7.3	
2. MM VII shocks occur at random once per 100 years along faults of total length 360 km	1800		2.2	
3. Probabilistic calculation by McGuire (20) based on historic events				
a. No upper bound on size of events	1000	3160	3.9	1.3
b. Excluding events of MM \geq IX	2240	7080	1.8	0.6

the data to larger magnitudes. We estimate that they may be uncertain by a factor of 2 to 3.

Using this log $N-m_b$ relationship, we derive in Table 1 (method 1) the recurrence times for MM intensities at the reactor site to equal or exceed intensities VII and VIII, for three different upper bounds on the size of possible earthquakes. The corresponding probabilities of equaling or exceeding intensities VII and VIII for an exposure interval of 40 years, the presumed lifetime of the nuclear power plants, are also tabulated.

First (method 1a) we calculate the contributions to site intensities only from earthquakes within 10 km of the site. The intensity at a distance of up to 10 km, for earthquakes of moderate size, is expected to be nearly the same as that at the epicenter (20). Thus, the probability that site intensity will equal or exceed, say, VII once in 40 years from earthquakes within 10 km of the site is equivalent to the probability of occurrence of earthquakes of MM \geq VII. For an earthquake more distant than 10 km the probability that its intensity at the site will equal or exceed a given intensity is a function of the size of the earthquake and the decay of intensity with distance. Approximating the fault zone as a line source, and assuming the intensity-distance relationship of McGuire (20) for the East Coast, we used the procedure developed by Cornell (21) in method 1b (Table 1) to integrate over the entire fault length. The probabilities of equaling or exceeding intensities VII and VIII thus calculated are not greatly affected by the use of a line instead of an areal source

but are sensitive to the intensity-distance relationship. Other attenuation curves (22), also considered appropriate for the eastern United States, give higher estimates than those in Table 1 (method 1b).

Table 1 shows that the calculated probabilities are not greatly dependent on the maximum size of earthquakes. Estimates obtained by excluding events of MM \geq IX, however, are probably more realistic. Thus, the probability that the MM intensity at the reactor site will equal or exceed VII, the design (safe shutdown) earthquake, once in 40 years is about 5 to 11 percent. For MM \geq VIII, the probability is about 2 percent.

Method 2 (Table 1) is a more approximate calculation based on the historic rate of occurrence of shocks of intensity VII in the greater New York City area. We take the rate as 2.5 shocks per 250 years since the 1927 event is assigned MM VII in one catalog (16) and VI in another (9). We assume that these shocks, like those in Fig. 2, occur along major northeast-trending faults, which we estimate have a total length about three times that of the Ramapo fault. Assuming a rupture length of about 5 km for MM VII (23), we obtain a total of 72 rupture segments, four of which we take as being within 10 km of Indian Point. This gives a recurrence time of 1800 years for MM VII within 10 km of the plants. This calculation suffers from our poor knowledge of the lengths of rupture zones for eastern earthquakes and of their extent in depth. Since precisely located shocks in the area have computed depths that are less than 11 km, the calculated recurrence time is not greatly affected by the

depth of seismic faulting in individual shocks.

McGuire (20) calculated probabilities for exceeding given intensities for a number of sites near the East Coast by randomly varying the locations of historic shocks within individual seismic provinces. He showed that his method is stable to uncertainties in the designation of seismic provinces and the size of specific shocks. The approach used in the federal siting appendix (7), however, is highly sensitive to those parameters. Differences of up to two MM intensity units can be obtained with the existing procedure, depending on how the seismic provinces are drawn. For a 10,000-year return period, McGuire calculated a shock of intensity 8.3 for New York City under the assumption that shocks larger than MM IX cannot occur. If his results are applied to Indian Point, we obtain return periods of 2240 and 7080 years (method 3, Table 1) for intensities VII and VIII, respectively. Some of his other calculations, which probably are not as realistic as the above, yield shorter return periods for the same intensities.

We think that method 1 provides the most realistic estimate since it is based on data from the area of the Ramapo fault, whereas in method 3 a random distribution of activity in space is assumed. Our best estimates are larger by about a factor of 10 than that computed by NRC seismologists (24) for the same intensity; their estimate suffers from an assumed random distribution of activity in space and much more limited data than that used in this study. The 5 to 11 percent probabilities we obtained, of course, should not be equated with the probability of significant damage or accidental radioactive release.

Indian Point reactors 2 and 3 are designed for an input acceleration of 15 percent of the earth's gravitational acceleration, g (25), for very high frequencies. The power plants, however, are situated within a few kilometers of branches of the Ramapo fault system, where earthquakes as shallow as 1 to 2 km occur. Now that we have demonstrated that the Ramapo fault is active, it is not clear whether nearfield accelerations, which can be as high as $0.5g$ at high frequencies for moderate-size earthquakes (26), have been adequately considered in the design of the reactors. The Advisory Committee on Reactor Safety of NRC recently recommended a minimum design of 20 percent of g for new reactors in the East (27).

We believe that our calculations provide the public and policy-makers with

quantitative numbers against which to judge whether the risk is acceptable or not. It is clear, however, that not a great many of the approximately 70 nuclear power plants now in operation in the United States can be allowed to operate at a risk of 5 to 11 percent without the probability becoming high that shaking will exceed that of the design earthquake for at least one of them over a 40-year period.

The Indian Point seismic hearings before NRC brought out a number of problems about the applicability of the existing federal regulations (7) to sites in the East. By these regulations a capable fault is defined on the basis of either (i) demonstrated fault movement younger than 500,000 years or (ii) macroseismicity instrumentally determined with records of sufficient precision to demonstrate a direct relationship with the fault. There is no evidence for surface breakage in any earthquake in the central or eastern United States, with the possible exception of questionable ground breakage during the New Madrid, Missouri, earthquakes of 1811–1812. Yet we know that a number of large and damaging shocks have occurred in these areas. The Ramapo fault is typical of many eastern sites in that almost all of the rocks in the region, with the exception of scattered postglacial deposits less than 15,000 years old, are older than 150×10^6 years. Hence, it is very difficult to tell if earth movements are as old as 150×10^6 years or if they happened in the past 0.5×10^6 years. Thus, surface breakage is not a good indicator of either “capability” or seismic risk for many eastern sites.

The hearings demonstrated that the word “macroseismicity,” which is not defined in the regulations, is rarely used or defined by seismologists. Various scientific witnesses differed to a large extent in their concept of macroseismicity (28). For much of the East, instrumental data of sufficient precision to demonstrate a relation to specific faults are very limited in time. Hence, it is not surprising that no fault in the central or eastern United States has as yet been declared legally capable.

In the absence of capable faults, the concept of “tectonic provinces” is used in deriving the intensity of the design earthquake from the historic record of shocks. The intensity at the site is calculated by moving historic shocks in the same province to the site and shocks in adjacent provinces to the closest point within those provinces (if the shocks cannot reasonably be correlated with a

tectonic structure). Although this procedure may appear conservative in terms of design safety, it is so only if reasonably large tectonic provinces are used. At the Indian Point hearings it was clear that the scientific witnesses had greatly varying opinions about the size, designation, and concept of tectonic provinces (28). These ambiguities can result in a number of small provinces being invoked to keep critical historic shocks at a distance such that their intensities at the site are much lower than those near the epicenter. In the case of Indian Point, this leads to a design earthquake of intensity VII or VIII depending on the designation of tectonic provinces.

The rate of seismic activity along the Ramapo fault and in the East in general is clearly less than that for major faults in, say, California or Japan. Although the federal siting regulations put the question of the capability of a fault as a yes-no decision, the present rate of movement along faults obviously varies by many orders of magnitude. We believe recognition must be given to the fact that some faults are more “capable” than others. Until this is done, the public may well equate the designation of capability with size and rate of occurrence of earthquakes like those along, say, the San Andreas fault in California. In the context of siting nuclear power plants and other critical facilities, we believe that the rate of activity must be judged in comparison to the design earthquake of the plant. The rate of activity along the Ramapo fault is such that it probably only warrants concern for critical facilities such as nuclear power plants and hospitals for which integrity must be ensured at a high level of confidence.

YASH P. AGGARWAL

Lamont-Doherty Geological Observatory of Columbia University, Palisades, New York 10964

LYNN R. SYKES

Lamont-Doherty Geological Observatory and Department of Geological Sciences, Columbia University, New York 10027

References and Notes

1. B. Isacks and J. Oliver, *Bull. Seismol. Soc. Am.* **54**, 1941 (1964); R. A. Page, P. H. Molnar, J. Oliver, *ibid.* **58**, 681 (1968); J. F. Davis, P. W. Pomeroy, R. H. Fakundiny, written statement, Geological Survey, New York State Museum and Science Service, regarding the licensing of Indian Point reactor 3, Albany, N.Y., 3 April 1974.
2. U.S. Atomic Energy Commission, *Final Environmental Statement Related to Operation of Indian Point Nuclear Generating Plant, Unit No. 2* (Directorate of Licensing, Washington, D.C., September 1972), vol. 1, p. II-26.
3. N. M. Ratcliffe, “Preliminary report on fault systems in vicinity of Indian Point, Peekskill and Haverstraw Quadrangles, N.Y.,” unpublished manuscript and covering letter to Consolidated

Edison, New York, Inc., 30 June 1975; “Safety evaluation report, Indian Point nuclear generating unit No. 3, supplement 2” (U.S. Nuclear Regulatory Commission, Washington, D.C., 12 December 1975), p. 2.

4. *Geotechnical Investigation of the Ramapo Fault System in the Region of the Indian Point Generating Station*, for Consolidated Edison of New York, Inc. (Dames and Moore, Consultants, Cranford, N.J., 28 March 1977), vols. 1 and 2.
5. N. M. Ratcliffe, *Final Report on Major Fault Systems in the Vicinity of Tompkins Cove-Buchanan, New York*, for Consolidated Edison of New York, Inc., New York, 24 June 1976.
6. L. R. Sykes, testimony on the capability of Ramapo fault before the Atomic Safety Licensing Appeal Board (ASLAB), Washington, D.C., 1976; Y. P. Aggarwal, testimony on behalf of New York State before ASLAB, 1977.
7. U.S. Atomic Energy Commission, “Appendix A, Seismic and geologic siting criteria for nuclear power plants,” *Fed. Regist.* **38**, 31279 (1973).
8. O. W. Nuttli, *J. Geophys. Res.* **78**, 876 (1973).
9. W. E. T. Smith, *Publ. Dom. Obs. Ottawa* **26**, 271 (1962); *ibid.* **32**, 87 (1966).
10. Y. P. Aggarwal, *Annual Technical Report to New York State Energy Research and Development Authority* (1977); in preparation; *EOS (Trans. Am. Geophys. Union)* **58**, 431 (1977) (abstract).
11. N. M. Ratcliffe, *Geol. Soc. Am. Bull.* **82**, 125 (1971).
12. L. R. Sykes, *EOS (Trans. Am. Geophys. Union)* in press; in preparation.
13. F. H. Jacobeen, Jr., *Md. Geol. Surv. Inf. Circ.* **13** (1972); *Geol. Soc. Am. Abstr. with Programs* **6**, 40 (1974); N. Spoljaric, R. R. Jordan, R. E. Sheridan, *Photogramm. Eng. Remote Sensing* **52**, 1069 (1976); H. J. Hansen, *Geology* **4**, 449 (1976); R. B. Mixon and W. L. Newell, *ibid.* **5**, 437 (1977).
14. W. J. McGee, *U.S. Geol. Surv. Annu. Rep.* **7**, 545 (1888); M. W. Higgins, I. Zeitz, G. W. Fisher, *Geology* **2**, 73 (1974).
15. C. R. Allen et al., *Bull. Seismol. Soc. Am.* **55**, 753 (1965).
16. J. L. Coffman and C. A. vonHake, *Earthquake History of the United States* (Publication 41-1, U.S. Department of Commerce, Washington, D.C., 1973).
17. C. G. Rockwood, Jr., *Am. J. Sci. (Ser. 3)* **29**, 425 (1885).
18. *Paterson Daily Press* (11 August 1884), p. 1.
19. Y. P. Aggarwal, in preparation.
20. R. K. McGuire, *Bull. Seismol. Soc. Am.* **67**, 827 (1977).
21. C. A. Cornell, *ibid.* **58**, 1583 (1968).
22. I. N. Gupta and O. W. Nuttli, *ibid.* **66**, 743 (1976); B. F. Howell and T. R. Schultz, *ibid.* **65**, 651 (1975); C. A. Cornell and H. A. Merz, *J. Struct. Div. Am. Soc. Civ. Eng.* **10**, 2027 (1975).
23. W. Thatcher and T. C. Hanks, *J. Geophys. Res.* **78**, 8547 (1973).
24. S. M. Coplan and R. B. Hofman, written memo, U.S. Atomic Energy Commission, 13 November 1974.
25. *Safety Evaluation Report, Indian Point Nuclear Generating Unit No. 3* (U.S. Nuclear Regulatory Commission, Washington, D.C., 21 September 1973); Dames and Moore, Consultants, testimony before ASLAB, 1976 and 1977. The Indian Point hearings before ASLAB generated considerable debate about what is the appropriate acceleration value for a design earthquake of intensity VII [(28)]; M. D. Trifunac, testimony on peak accelerations and intensity before ASLAB, Washington, D.C., 1976). For this report, we equate 15 percent of g with intensity VII.
26. T. C. Hanks and D. A. Johnson, *Bull. Seismol. Soc. Am.* **66**, 959 (1976).
27. Letter from the chairman of the Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards to the chairman of the Nuclear Regulatory Commission (17 January 1977).
28. Atomic Safety Licensing Appeal Board, U.S. Nuclear Regulatory Commission, Decision ASLAB-436, 12 October 1977.
29. D. W. Fisher, Y. W. Isachsen, L. V. Rickard, geologic map of New York State, Lower Hudson Sheet (1970); H. B. Kummel and M. E. Johnson, geologic map of New Jersey (1950).
30. We thank J. Davis, P. Pomeroy, N. Ratcliffe, C. Scholz, R. Page, K. Jacob, L. Seeber, J. Anderson, and M. Trifunac for critically reading the report and for helpful discussions. Supported by grants from the National Science Foundation, the U.S. Nuclear Regulatory Commission, and the New York State Energy Research and Development Authority. Lamont-Doherty Geological Observatory Contribution No. 2615.

19 December 1977; revised 28 February 1978